



## **GAS JANITOR**

a true safety

### AMMONIA LEAKAGE DETECTOR-GJ0417

#### **Description:**

The **GJ0417** is a wall mounted or fixed type Ammonia leakage detector. This device senses the Ammonia gas leakage and gives LED indication and send signal to control panel also. Detectors and control panel connected with four core cables. And it is installed near gas leakage points. This device is also compatible to operate solenoid valve, Hooter, Siren, Fire Panel and BMS with some customization.



#### **Features:**

- **Widely installed in many industries**
- **Four wire communication two for power and remains two for Output.**
- **Protection against wrong wire connection and over range.**
- **MCU Based**
- **Fast Response**
- **Simple installation and maintenance**
- **Weatherproof & Flameproof enclosure**

**ADDICT AUTOMATION INDIA PVT LTD**  
**53/B2, 2<sup>ND</sup> FLOOR, RAMA ROAD INDUSTRIAL AREA, NEW DELHI-110015**  
**[WWW.GASJANITOR.COM](http://WWW.GASJANITOR.COM)**  
**EMAIL: [INFO@GASJANITOR.COM](mailto:INFO@GASJANITOR.COM), [ADDICTAUTOMATION17@GMAIL.COM](mailto:ADDICTAUTOMATION17@GMAIL.COM)**

# TECHNICAL DATA SHEET




# GAS JANITOR

a true safety

## Technical Specifications:

• Detection Principle	:	Semiconductor
• Sampling	:	Diffusion
• Range	:	up to 300 PPM
• Power Supply	:	24 VDC
• Power (MAX)	:	350 mA @ 24VDC
• Environmental Temperature	:	0 to 55°C
• Environmental Humidity	:	95% (Non-Condensing)
• Output	:	SPDT
• Alarm Level	:	30 PPM
• Response Time	:	<10 Sec
• Enclosure Class	:	IP66
• Mechanical Interface	:	3/4" NPT Three Side
• Total Dimensions	:	(L)180mm*(W)180mm*(H)100mm
• Color	:	TOP GRAY & BOTTOM YELLOW
• Housing Material	:	Aluminium Alloy
• Certificate	:	CMRI, BIS,PESO(CCOE)

## Installation Reference:



**ADDICT AUTOMATION INDIA PVT LTD**  
**53/B2, 2<sup>ND</sup> FLOOR, RAMA ROAD INDUSTRIAL AREA, NEW DELHI-110015**  
[WWW.GASJANITOR.COM](http://WWW.GASJANITOR.COM)  
**EMAIL: [INFO@GASJANITOR.COM](mailto:INFO@GASJANITOR.COM), [ADDICTAUTOMATION17@GMAIL.COM](mailto:ADDICTAUTOMATION17@GMAIL.COM)**